

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1 CONTRACT ID CODE	PAGE OF PAGES	
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 01 JAN 09	4. REQUISITION/PURCHASE REQ. NO. N/A	5. PROJECT NO. (If applicable) N/A	
6 ISSUED BY DEFENSE ENERGY SUPPORT CENTER (DESC) 8725 JOHN J. KINGMAN RD STE 3815 FORT BELVOIR VA 22060-6222 BUYER/SYMBOL: Nancy Barnett/DESC-PLC e-mail: nbarnett@dsc.dla.mil P.P.: 3.10 PHONE: 703-767-9529 FAX: 703-767-8506		CODE SP0600	7 ADMINISTERED BY (If other than Item 6)		CODE SP0600
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code) e-mail: POC: PHONE: FAX: CAGE CODE: DUNS#: BIDDER CODE: TAX ID:			(✓)	9A. AMENDMENT OF SOLICITATION NO. SP0600-00-R-0078	
			X	9B. DATED (SEE ITEM 11) 00 AUG 10	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<p>● The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ● is extended, ○ is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF					
D. OTHER Specify type of modification and authority)					
E. IMPORTANT: Contractor ○ is not, ○ is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
<p>A. The purpose of this amendment is to add Contract Clause C16.18-6 GASOLINE, AUTOMOTIVE, UNLEADED (REGULAR/MIDGRADE/PREMIUM) for compliance with ONLY Line Item 950-24/28 - BARBERS POINT.</p> <p>B. The following changes are made to this solicitation:</p> <p>(1) <u>Replace</u> Pages <u>29</u> and <u>30</u> of this solicitation with the attached revised pages;</p> <p>(2) Page 54 of the Solicitation - Contract Clause C16.18-6 GASOLINE, AUTOMOTIVE, UNLEADED (REGULAR/MIDGRADE/PREMIUM) is hereby added to the solicitation and is included in full text.</p> <p>C. ACKNOWLEDGEMENT OF ALL AMENDMENTS: All offerors must acknowledge receipt and acceptance of all amendments to the solicitation. You may do this by signing/completing Blocks 15A, B, and C of the Standard Form 30, Amendment of Solicitation / Modification of Contract, and returning the amendment or by written acknowledgment of receipt and acceptance as part of the offeror submission package.</p> <p style="text-align: center;">CONTINUED ON NEXT PAGE</p> <p style="text-align: center;">Except as provided herein, all terms and conditions of the document referenced in Items 9A or 10A, as heretofore changed, remain unchanged and in full force and effect.</p>					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
_____ (Signature of person authorized to sign)			BY _____ (Signature of Contracting Officer)		

ITEM NUMBER		ESTIMATED QUANTITY	UI	OFFER PRICE/ USG
-------------	--	--------------------	----	------------------

DEFENSE ENERGY SUPPORT CENTER

BARBERS POINT

HI, DESC, MSC, ISLAND OF OAHU

HONOLULU COUNTY

DELIVERY DODAAC: **SJ0600**
 BILLING DODAAC: **HD1121, W811AC, W81Y9R, 149233**
 ORDERING OFFICE: **808-477-6692**

950-24	GASOHOL, REG UNL (GUR)	1,020,000	GL	\$
---------------	-------------------------------	------------------	-----------	-----------

FOB ORIGIN (FOB), PIER SIDE AND TRUCK LOADING RACK INTO MSC CHARTERED MARINE VESSEL AT BARBERS POINT PIER

MUST BE IN COMPLIANCE WITH CONTRACT CLAUSE C16.18-6

MINIMUM DELIVERY: 21,000 GALLONS

MAXIMUM DELIVERY: 294,000 GALLONS

NOTE: MINIMUM PUMP RATE OF 1,000 BPH IS REQUIRED

FOR PIER SIDE "PIPELINE" LOADING (WHETHER PRODUCT IS LOADED ONTO A VESSEL EITHER BY PIPELINE OR BY TANK TRUCK).

THE SHORE TANK USED MUST BE SAMPLED. IF FOUND TO BE HOMOGENEOUS AND THE PIER PIPELINE IS CAPABLE OF BEING RECIRCULATED WITH SHORE TANK PRODUCT, THEN FULL SPECIFICATION TESTING WILL BE PERFORMED ON THE SHORE TANK SAMPLE.

IF THAT TANK IS FOUND NOT TO BE HOMOGENEOUS (EG: STRATIFIED), OR IF PIER PIPELINE IS INCAPABLE OF BEING RECIRCULATED WITH SHORE TANK PRODUCT, THEN THE CONTRACTOR WILL BE RESPONSIBLE FOR PRODUCT QUALITY ONBOARD THE VESSEL, HAVING FULL SPECIFICATION TESTING PERFORMED ON THE VESSEL COMPOSITE.

IF THE SPEC TEST RESULTS ARE NOT AVAILABLE BEFORE THE VESSEL RELEASE DATE, THEY MAY BE SUPPLIED TO THE COGNIZANT QAR NO LATER THAN 72 HRS AFTER THE VESSEL RELEASE DATE/TIME ANNOTATED ON THE DD250-1, AND PRIOR TO VESSEL DISCHARGE. FINAL GOVT ACCEPTANCE OF PRODUCT WILL NOT TAKE PLACE UNTIL THE FINAL TEST RESULTS ARE RECEIVED.

THIS ITEM IS DESC FUNDED
THIS FUEL IS CAPITALIZED

ITEM NUMBER	GASOLINE, REG UNL (MUR)	ESTIMATED QUANTITY	UI	OFFER PRICE/ USG
950-28	GASOLINE, REG UNL (MUR)	0	GL	\$

FOB ORIGIN (FOB), PIER SIDE AND TRUCK LOADING RACK INTO MSC CHARTERED MARINE VESSEL AT BARBERS POINT PIER

MUST BE IN COMPLIANCE WITH CONTRACT CLAUSE C16.18-6

MINIMUM DELIVERY: 21,000 GALLONS

MAXIMUM DELIVERY: 294,000 GALLONS

NOTE: MINIMUM PUMP RATE OF 1,000 BPH IS REQUIRED

FOR PIER SIDE "PIPELINE" LOADING (WHETHER PRODUCT IS LOADED ONTO A VESSEL EITHER BY PIPELINE OR BY TANK TRUCK).

THE SHORE TANK USED MUST BE SAMPLED. IF FOUND TO BE HOMOGENEOUS AND THE PIER PIPELINE IS CAPABLE OF BEING RECIRCULATED WITH SHORE TANK PRODUCT, THEN FULL SPECIFICATION TESTING WILL BE PERFORMED ON THE SHORE TANK SAMPLE.

IF THAT TANK IS FOUND NOT TO BE HOMOGENEOUS (EG: STRATIFIED), OR IF PIER PIPELINE IS INCAPABLE OF BEING RECIRCULATED WITH SHORE TANK PRODUCT, THEN THE CONTRACTOR WILL BE RESPONSIBLE FOR PRODUCT QUALITY ONBOARD THE VESSEL, HAVING FULL SPECIFICATION TESTING PERFORMED ON THE VESSEL COMPOSITE.

IF THE SPEC TEST RESULTS ARE NOT AVAILABLE BEFORE THE VESSEL RELEASE DATE, THEY MAY BE SUPPLIED TO THE COGNIZANT QAR NO LATER THAN 72 HRS AFTER THE VESSEL RELEASE DATE/TIME ANNOTATED ON THE DD250-1, AND PRIOR TO VESSEL DISCHARGE. FINAL GOVT ACCEPTANCE OF PRODUCT WILL NOT TAKE PLACE UNTIL THE FINAL TEST RESULTS ARE RECEIVED.

**THIS ITEM IS DESC FUNDED
THIS FUEL IS CAPITALIZED**

**NOTE: THIS IS AN ALTERNATE LINE ITEM FOR ITEM 950-24.
AWARD WILL BE MADE AT THE OVERALL LEAST COST TO THE GOVERNMENT.**

.....

Product shall conform to ASTM D 4814 with the following additional requirements:

(a) **OCTANE REQUIREMENT.** The Government's octane requirement is expressed by the Anti-Knock Index (AKI). The AKI is the average of the research octane number (RON) and the motor octane number (MON). The minimum AKI values are identified in (b) below. If the AKI value is not reported, then the RON value and the sensitivity of the fuel shall be reported. The sensitivity is the difference between the RON and the MON. The sensitivity of the fuel shall be 10 or less.

(b) **PRODUCT CLASSIFICATION.** The product shall be classified as described below:

NATIONAL STOCK NUMBER	PRODUCT NOMENCLATURE	AKI, MINIMUM
9130-00-148-7103	Gasoline, Regular, Unleaded	87
9130-01-272-0983	Gasoline, Midgrade, Unleaded	89
9130-00-148-7104	Gasoline, Premium, Unleaded	91

(c) **VAPOR PRESSURE.** The volatility class shall be as stated in the Schedule.

(d) **ADDITIVES.** Additives and additive concentration shall be as specified below. Application for approval of additives not listed below should be made to DESC-BP.

(1) **OXIDATION INHIBITORS.** The gasoline shall contain not less than five pounds nor more than 15 pounds of oxidation inhibitor (active ingredient) per 1,000 barrels of gasoline. Any one of a combination of the following oxidation inhibitors may be used:

- (i) N,N' disecundary butyl-para-phenylenediamine
- (ii) N,N' di-isopropyl-paraphenylenediamine
- (iii) N,N' dioctyl-para-phenylenediamine
- (iv) N,N' -bis-(1,4-dimethylpentyl)-para-phenylenediamine
- (v) N,N' disecundary butyl-ortho-phenylenediamine
- (vi) 2,6-ditertiary-butyl phenol
- (vii) 2,6-ditertiary-butyl-4-methylphenol
- (viii) 2,4-dimethyl-6-tertiary butyl phenol
- (ix) Triethylene tetramine di(monononyphenolate)
- (x) Mixed tertiary butyl phenols
- (xi) N, secondary butyl, N, pheny-ortho-phenylenediamine
- (xii) Mixed 2,6-dialkyl and 2,4,6-trialkyl phenols (containing mixed hexyl and heptyl groups)
- (xiii) 2,4-ditertiary-butylphenol (60 weight percent minimum) and mixed tertiary butyl phenols (40 weight percent maximum)
- (xiv) 2,4-ditertiary-butylphenol (containing mono tritertiary butyl phenol)
- (xv) Butylated ethyl phenols (55 weight percent minimum) and butylated methyl and dimethyl phenols (45 weight percent maximum)

(2) **METAL DEACTIVATORS.** The gasoline shall contain not less than one pound nor more than three pounds of an approved metal deactivator (active ingredient) per 1,000 barrels of gasoline. Any one of the following metal deactivators may be added separately or in combination with an approved oxidation inhibitor:

- (i) N,N' disalicylidene -1,2-ethanediamine
- (ii) N,N' disalicylidene -1,2-propanediamine
- (iii) N,N' disalicylidene -1,2-cyclohexanediamine
- (iv) Disalicylidene-N-methyl-dipropylene-triamine

(3) **CORROSION INHIBITOR.** An approved corrosion inhibitor may be added. Any corrosion inhibitor used shall be a product that is qualified under MIL-I-25017. The quantity added shall not exceed the maximum approved in the qualified products list (QPL-25017).

(e) **WATER TOLERANCE REQUIREMENT.** The maximum temperature for phase separation as determined by the water tolerance test shall be 10°C.

(DESC 52.246-9FHK)