

|   |  |   |  |                                      |
|---|--|---|--|--------------------------------------|
| <b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>   |  |   | 1. CONTRACT ID CODE  | PAGE OF PAGES<br><b>1</b>   <b>2</b> |
| 2. AMENDMENT/MODIFICATION NO.<br><b>0004</b>  | 3. EFFECTIVE DATE<br><b>4 DEC 2003</b> | 4. REQUISITION/PURCHASE REQ. NO.<br>SC0600-03-0026 AMD 001 - 004  | 5. PROJECT NO. (If applicable)                               |                                      |
| 6. ISSUED BY<br><b>DEFENSE ENERGY SUPPORT CENTER<br/>8725 JOHN J. KINGMAN ROAD, SUITE 2954<br/>FT. BELVOIR, VIRGINIA 22060-6222<br/>BUYER: CHRISTINE HOPPER/ DESC-BZA<br/>PHONE: (703) 767-9254 FAX: (703) 767-9269</b>   | CODE<br><b>SP0600</b>                  | 7. ADMINISTERED BY (If other than Item 6) CODE  |  |                                      |
| 8. NAME AND ADDRESS OF CONTRACTOR (NO., street,city,county,State,and ZIP Code)  |  | (i)   | 9A. AMENDMENT OF SOLICITATION NO.<br><b>SP0600-04-R-0061</b> |                                      |
|   |  | <b>X</b>  | 9B. DATED (SEE ITEM 11)<br><b>24 SEPTEMBER 2003</b>          |                                      |
|   |  |   | 10A. MODIFICATION OF CONTRACT/ORDER NO.                      |                                      |
|   |  |   | 10B. DATED (SEE ITEM 13)                                     |                                      |
| CODE  | FACILITY CODE                          |   |  |                                      |
| <b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>  |  |   |  |                                      |
| <p>[ X ] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended [ X ] is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted ; or (c) by separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p> |  |   |  |                                      |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required)   |  |   |  |                                      |
| <b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>   |  |   |  |                                      |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.  |  |   |  |                                      |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)   |  |   |  |                                      |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:  |  |   |  |                                      |
| D. OTHER (Specify type of modification and authority)   |  |   |  |                                      |
| E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return ___ copies to the issuing office.   |  |   |  |                                      |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)   |  |   |  |                                      |
| <p><b>THIS AMENDMENT IS AVAILABLE ON DESC'S WEBSITE AT <a href="http://www.desc.dla.mil">http://www.desc.dla.mil</a> OR <a href="http://www.fedbizopps.gov">http://www.fedbizopps.gov</a></b></p> <p style="text-align: center;"><b>SEE CONTINUATION PAGES</b></p> <p>Except as provided herein, all terms and conditions of the document referenced in Items 9A or 10A, as heretofore changed, remain unchanged and in full force and effect.</p>  |  |   |  |                                      |
| 15A. NAME AND TITLE OF SIGNER (Type or print)   |  | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)<br><b>WILLIAM A. MACLAREN JR.<br/>Contracting Officer, Bulk Fuels Division</b> |  |                                      |
| 15B. CONTRACTOR/OFFEROR<br><br>(Signature of person authorized to sign)   | 15C. DATE SIGNED                       | 16B. UNITED STATES OF AMERICA<br><br>_____  | 16C. DATE SIGNED   |                                      |
|   |  | (Signature of Contracting Officer)  |  |                                      |

The **Solicitation Package** is revised as follows:

1. Page 2 and Page 87: Clause C16.23 is hereby deleted and replaced with the attached Clause C16.23 FUEL, NAVAL DISTILLATE (F76)(DESC NOV 2003).

**C16.23 FUEL, NAVAL DISTILLATE (F76) (DESC NOV 2003)**

Military Specification MIL-PRF-16884K dated November 14, 2002, applies with the following modifications:

(a) **STABILIZER ADDITIVE.** Line injection of stabilizer additive is permitted under the following conditions:

(1) A laboratory hand blend containing the additive F76 must be tested to verify compliance with all specification requirements.

**(2) The additive must be proportionately injected throughout the entire loading process to ensure the additive is homogeneously blended into the F76. The Contractor shall maintain records evidencing the homogenous blending of the line injected additive. Such methods may include meter or tank gauge readings taken at intervals to provide confidence in the injection process.**

(b) **REPORTS.** Refer to the MATERIAL INSPECTION AND RECEIVING REPORT clause for reporting requirements.

In addition, copies of the applicable DD Form 250 or DD Form 250-1 shall be submitted with a laboratory analysis report for each tank of product lifted. This documentation shall be submitted to the address identified in the MATERIAL INSPECTION AND RECEIVING REPORT clause and the address shown below:

NAVY SEA SYSTEMS COMMAND  
SEA 05M3  
1333 ISAAC HULL AVENUE SE  
WASHINGTON NAVY YARD, DC 20376  
UNITED STATES

NAVAL AIR SYSTEMS COMMAND  
FUELS AND LUBRICANTS DIVISION, AIR 4.4.5  
22229 ELMER ROAD, UNIT 4, BLDG 2360  
PATUXENT RIVER, MD 20670-1534

(c) **RED DYE. (Does not apply to Atlantic/Europe/Mediterranean or Western Pacific Overseas Bulk purchase programs unless offering refinery is located in the United States or one of its possessions.)** Red dye required in off-highway diesel fuel in accordance with 40 CFR Part 80 as modified by the Environmental Protection Agency's interim final rule published in the Federal Register dated July 14, 1994, shall not be added to F76 supplied. The finished product shall show no visual evidence of red dye. This product is for military, off-highway use only and must be segregated at all times from any diesel fuel used on-highway.

(d) **OXYGEN OVERPRESSURE TESTING. The maximum total insolubles limited applicable to accelerated storage stability results generated by ASTM method D 5304 is 3.0 milligrams per 100 milliliters of sample. This limit is changed from the previously-specified 1.5 mg/100 ml limit due to a change in the type of filter media required in the latest (2002) version of this test method. Only nylon membrane filter media (0.8 micron pore size) are acceptable as specified in the latest revision of ASTM D 5304. Do not use glass fiber (Type A/E) filter media to obtain test results by ASTM method D 5304.**

(DESC 52.246-9FBE)