

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 9 PAGES	
2. AMENDMENT/MODIFICATION NO. <b>0004</b>		3. EFFECTIVE DATE		4. REQUISITION/PURCHASE REQ. NO. <b>SP0600-02-0102</b>		5. PROJECT NO. (If applicable) <b>PUERTO RICO/ VIRGIN ISLANDS</b>
6. ISSUED BY <b>DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN ROAD, SUITE 4950 FT BELVOIR, VA 22060-6222 FAX: 703-767-8506 P. BURKE / DESC-PLB 703-767-9503</b>		CODE <b>SP0600</b>		7. ADMINISTERED BY (If other than Item 6)		CODE
				P.P. 3.11		
8. NAME AND ADDRESS OF CONTRACTOR (NO., street,city,county,State,and ZIP Code)				<input checked="" type="checkbox"/>		9a. AMENDMENT OF SOLICITATION NO. <b>SP0600-02-R-0024</b>
						9b. DATED (SEE ITEM 11) <b>29 NOVEMBER 2001</b>
						10a. MODIFICATION OF CONTRACT/ORDER NO.
						10b. DATED (SEE ITEM 13)
BIDDER CODE:		CAGE CODE:				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment;(b) By acknowledging receipt of this amendment on each copy of the offer submitted; or(c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
2. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copy to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <b>PUERTO RICO/VIRGIN ISLANDS Purchase Program 3.11</b>						
<b>A. This is Amendment 0004 to the Solicitation. All Offerors must acknowledge receipt of this amendment by completing block 8 above, signing and dating blocks 15A, 15B, and 15C. below. Please submit completed copy of page 1 to DESC-PLC via facsimile at (703) 767-8506. The Closing Date of 10 January 2002 is <u>not</u> extended.</b>						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER <b>KATHRYN R. RISO</b>		
15B. NAME OF CONTRACTOR/OFFEROR <b>BY _____</b> (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA <b>BY _____</b> (Signature of Contracting Officer)		16C. DATE SIGNED

B. The **delivery narratives** of the following line items **are changed** from Tank Truck (TT) to Tank Wagon (TW) deliveries. Tank sizes at these facilities do not allow for TT truckloads, within the terms of the Solicitation, at these locations. Note that all Tank Wagon deliveries may require Multiple Drop (delivery into more than one tank) pursuant to Clause F1.01-1 DELVIERY CONDITIONS FOR TRANSPORT TRUCKS, TRUCKS AND TRAILERS, AND TANK WAGONS (DESC APR 1997)

ITEM NUMBER		ESTIMATED QUANTITY UI
	----- ARMY NATIONAL GUARD -----  SALINAS, PR, ARMY NG, HHD SALINAS TRAINING SITE, ANNUAL FIELD TRAINING, CAMP SANTIAGO, BUILDING 100, (FOR USPFO, PUERTO RICO) SALINAS MUNICIPALITY DELIVERY DODAAC: W80290 BILLING DODAAC : WF3SCY ORDERING OFFICE: 787-793-0909 EXT 228	
251-24	GASOHOL, REG UNL (GUR) ***PORTS ACTIVE***  TANK WAGON (TW), W/DACO CERTIFICATION INTO 1/2,000 GALLON TANK ANTICIPATE 50% ON HIGHWAY USE DELIVERY TICKET REQUIRED DELIVERY HOURS: 0730-1500 / 7 DAYS EXCLUDING HOLIDAY	20,000 GL
251-28	GASOLINE, REG UNL (MUR) ***PORTS ACTIVE***  TANK WAGON(TW), W/DACO CERTIFICATION INTO 1/2,000 GALLON TANK ANTICIPATE 50% ON HIGHWAY USE DELIVERY TICKET REQUIRED DELIVERY HOURS: 0730-1500 7 DAYS EXCLUDING HOLIDAY NOTE: THIS IS AN ALTERNATE LINE ITEM FOR ITEM 251-24. AWARD WILL BE MADE AT THE OVERALL LEAST COST TO THE GOVERNMENT.	0 GL

ITEM  
 NUMBER

ESTIMATED  
 QUANTITY UI

-----  
 UNITED STATES NAVY  
 -----

CEIBA,  
 PR, NAVY, ROOSEVELT ROADS, NAVAL STATION  
 HUMACAO DISTRICT  
 DELIVERY DODAAC: N00389  
 BILLING DODAAC : N00389  
 ORDERING OFFICE: 787-865-4080

550-681 DIESEL FUEL #2, LOW SULF (LS2) 1,152,000 GL  
 \*\*\*PORTS ACTIVE\*\*\*

TANK TRUCK (TT), INTO  
 1/5,000 GALLON TANK BLDG 1808, GALLEY BOILER  
 1/1,000 GALLON TANK BLDG 1808, GALLEY  
 1/250 GALLON TANK BLDG 1796, EXCHANGE  
 1/1,000 GALLON TANK BLDG 1688, BOQ  
 1/250 GALLON TANK BLDG 1685, COMSOLANT  
 1/100 GALLON TANK BLDG 2282, NSWU4  
 1/100 GALLON TANK BLDG 2276, NSWU4  
 1/100 GALLON TANK MEDICAL BLDG 2277, NSWU4  
 1/100 GALLON TANK BLDG 792, DIVE LOCKER, NSWU4  
 1/100 GALLON TANK BLDG 2234, DIVE LOCKER, NSWU4  
 1/400 GALLON TANK BLDG 598, BASE ADMINISTRATION  
 1/250 GALLON TANK BLDG 296, RADIO STA  
 1/1,000 GALLON TANK BLDG 31, PUBLIC WORKS  
 1/1,500 GALLON TANK BLDG 2045, RADAR SITE  
 1/250 GALLON TANK BLDG 1807, SECURITY DISPATCH  
 1/2,000 GALLON TANK BLDG 1757, WATER TREATMENT PLANT  
 1/250 GALLON TANK BLDG 646, GATE #3  
 1/250 GALLON TANK BLDG 1209, BARRACKS  
 1/2,000 GALLON TANK BLDG 2302, SECURITY (A/F)  
 1/1,000 GALLON TANK BLDG 731, BUNDY BARRACKS  
 1/1,000 GALLON TANK BLDG 732, BUNDY BARRACKS  
 1/1,000 GALLON TANK BLDG 733, BUNDY BARRACKS  
 1/1,000 GALLON TANK BLDG 734, BUNDY BARRACKS  
 1/350 GALLON TANK BLDG 827, BRAVO BASE  
 1/500 GALLON TANK BLDG 860, DRONE SHOP  
 1/560 GALLON TANK BLDG 2339, MINI MART  
 1/100 GALLON TANK BLDG 1207, SUPPLY  
 1/75 GALLON TANK BLDG 2252, SURFACE OPS  
 1/2,000 GALLON TANK BLDG 2394, COMMISARY  
 1/250 GALLON TANK BLDG 1203, GATE #1  
 1/550 GALLON TANK BLDG 1758, HOUSING TREATMENT PLANT  
 1/250 GALLON TANK BLDG 2314, MWR  
 1/500 GALLON TANK BLDG 2415, FUEL SUPPORT CRASH CREW  
 1/500 GALLON TANK BLDG 2369, CRASH RESCUE  
 1/1,000 GALLON TANK BLDG 560, SOCSOUTH  
 1/700 GALLON TANK BLDG 1686, FBI  
 1/250 GALLON TANK BLDG 519, 7TH AB  
 1/250 GALLON TANK BLDG 2357, USMC  
 1/100 GALLON TANK BLDG 2439, HOUSING OFFICE  
 1/2,500 GALLON TANK BLDG 1090A, MSR MARINA  
 1/1,500 GALLON TANK BLDG 1090B, MWR MARINA  
 1/70 GALLON TANK BLDG 1810, HOSPITAL  
 1/1,250 GALLON TANK BLDG 1810, HOSPITAL

-----  
UNITED STATES NAVY  
-----

550-681

Continued

1/6,000 GALLON BELOW GROUND TANK BLDG 124, TANK  
124C, FUELS DIV SERVICE STATION  
1/2,000 GALLON TANK BLDG 2394, COMMISSARY REEFERS  
1/550 GALLON ABOVE GROUND TANK(S) BLDG 2019, PWD  
EMERGENCY GENERATOR  
1/1,000 GALLON ABOVE GROUND TANK(S) BLDG 3047, AST  
3138, CAMP MOSCRIP BOILER  
1/250 GALLON ABOVE GROUND TANK(S) BLDG 827, AST  
827B, CRASH CREW FIRE TRAINING  
1/350 GALLON ABOVE GROUND TANK(S) BLDG 2369, AST  
2370, CRASH CREW EMERGENCY GENERATOR  
1/2,500 GALLON BELOW GROUND TANK BLDG 124, TANK  
124A, FUEL DIV SERVICE STATION  
1/1,000 GALLON TANK BLDG 729, VAST, PWD BOILER  
1/1,000 GALLON TANK BLDG 731, VAST, PWD BOILER  
1/1,000 GALLON TANK BLDG 732, VAST, PWD BOILER  
1/1,000 GALLON TANK BLDG 733, VAST, PWD BOILER  
1/1,000 GALLON TANK BLDG 734, VAST, PWD BOILER  
1/4,000 GALLON BELOW GROUND TANK BLDT 774, PWD  
EMERGENCY GENERATOR  
1/550 GALLON TANK BLDG 790, PWD EMERGENCY  
GENERATOR  
1/310 GALLON TANK BLDG 798, PWD EMERGENCY  
GENERATOR  
1/500 GALLON BELOW GROUND TANK BLDG 88, PWD  
EMERGENCY GENERATOR  
1/1,000 GALLON BELOW GROUND TANK BLDG EARTH, PWD  
EMERGENCY GENERATOR  
1/2,000 GALLON TANK BLDG 1729, VAST, AFWTF  
EMERGENCY GENERATOR  
1/5,000 GALLON TANK BLDG 2014, VAST, AFWTF  
EMERGENCY GENERATOR  
1/600 GALLON TANK BLDG 2037, VAST, AFWTF EMERGENCY  
GENERATOR  
1/350 GALLON TANK BLDG 2228, VAST, AFWTF EMERGENCY  
GENERATOR  
1/5,000 GALLON TANK BLDG 2293, EMERGENCY GENERATOR  
1/300 GALLON TANK BLDG 296, VAST, AFWTF EMERGENCY GENERATOR  
1/400 GALLON ABOVE GROUND TANK(S) BLDG 2021, PWD  
EMERGENCY GENERATOR  
1/1,000 GALLON TANK BLDG 2302, VAST, PWD EMERGENCY GENERATOR  
1/750 GALLON TANK BLDG 2303, VAST, PWD BOILER  
1/610 GALLON TANK BLDG 2303 AST 2303EX, PWD BOILER  
1/550 GALLON BELOW GROUND TANK BLDG 2357, PWD BOILER  
1/360 GALLON ABOVE GROUND TANK(S) BLDG 2360, PWD  
EMERGENCY GENERATOR  
1/310 GALLON ABOVE GROUND TANK(S) BLDG 2361, PWD  
EMERGENCY GENERATOR  
1/200 GALLON ABOVE GROUND TANK(S) BLDG 2394, AST  
2394A, PWD EMERGENCY GENERATOR  
1/2,000 GALLON ABOVE GROUND TANK(S) BLDG 2360, AST  
2394B, PWD EMERGENCY GENERATOR  
1/250 GALLON ABOVE GROUND TANK(S) BLDG 296, PWD  
EMERGENCY GENERATOR  
1/1,000 GALLON ABOVE GROUND TANK(S) BLDG 31, AST  
31-1, PWD EMERGENCY GENERATOR

-----  
UNITED STATES NAVY  
-----

550-681 Continued

1/250 GALLON ABOVE GROUND TANK(S) BLDG 460, PWD  
EMERGENCY GENERATOR  
1/550 GALLON ABOVE GROUND TANK(S) BLDG 542, PWD  
EMERGENCY GENERATOR  
1/250 GALLON ABOVE GROUND TANK(S) BLDG 161, PWD  
EMERGENCY GENERATOR  
1/10,000 GALLON BELOW GROUND TANK BLDG 1686, PWD BOILER  
1/1,000 GALLON ABOVE GROUND TANK(S) BLDG 1691,  
AFWTF EMERGENCY GENERATOR  
1/1,000 GALLON ABOVE GROUND TANK(S) BLDG 2019,  
AFWTF EMERGENCY GENERATOR  
ANTICIPATE 0% ON HIGHWAY USE  
LOADING RACK METERED DELIVERY TICKET REQUIRED  
DELIVERY HOURS: 0700-1530 MONDAY THRU FRIDAY  
**AUTOMATIC FILL**  
THIS FUEL IS CAPITALIZED  
UPON ENTERING THE BASE PROCEED TO BUILDING 192,  
FUELS OFFICE FOR ACCEPTANCE

EL YUNQUE,  
PR, NAVY, FAA, WAAS RADAR, RCAG BUILDING, PICO DEL ESTE  
RIO GRANDE MUNICIPALITY  
DELIVERY DODAAC: N0017A  
BILLING DODAAC : N0017A  
ORDERING OFFICE: 787-865-4317

600-68 DIESEL FUEL #2, LOW SULF (LS2) 68,000 GL  
\*\*\*PORTS ACTIVE\*\*\*

TANK WAGON (TW), W/DACO CERTIFICATION INTO  
1/10,000 GALLON TANK  
1/3,000 GALLON TANK  
1/1,000 GALLON TANK  
ANTICIPATE 0% ON HIGHWAY USE  
DELIVERY TICKET REQUIRED FOR EACH TANK  
NOTE: FUEL USED IN GENERATORS.

ITEM NUMBER		ESTIMATED QUANTITY	UI
	----- UNITED STATES NAVY -----		
	VIEQUES ISLAND, PR, NAVY, CERRO MATIAS VIEQUES MUNICIPALITY DELIVERY DODAAC: N0017A BILLING DODAAC : N0017A ORDERING OFFICE: 787-865-4317/7023		
655-24	GASOHOL, REG UNL (GUR) ***PORTS ACTIVE***	20,000	GL
	TANK WAGON (TW), W/DACO CERTIFICATION INTO 2/4,000 GALLON TANKS ANTICIPATE 60% ON HIGHWAY USE DELIVERY TICKET REQUIRED FOR EACH TANK		
655-28	GASOLINE, REG UNL (MUR) ***PORTS ACTIVE***	0	GL
	TANK WAGON (TW), W/DACO CERTIFICATION INTO 2/4,000 GALLON TANKS ANTICIPATE 60% ON HIGHWAY USE DELIVERY TICKET REQUIRED FOR EACH TANK NOTE: THIS IS AN ALTERNATE LINE ITEM FOR ITEM 655-24. AWARD WILL BE MADE AT THE OVERALL LEAST COST TO THE GOVERNMENT.		
655-68	DIESEL FUEL #2, LOW SULF (LS2) ***PORTS ACTIVE***	100,000	GL
	TANK WAGON (TW), W/DACO CERTIFICATION INTO 1/15,000 GALLON TANK 1/4,000 GALLON TANK ANTICIPATE 0% ON HIGHWAY USE DELIVERY TICKET REQUIRED FOR EACH TANK NOTE: FUEL USED IN GENERATORS.		

SP0600-02-R-0024  
 AMENDMENT 004

ITEM NUMBER		ESTIMATED QUANTITY	UI
	----- UNITED STATES POSTAL SERVICE -----		
	PONCE, PR, USPS, 00731-9999, VMF, AUX GARAGE PONCE MUNICIPALITY DELIVERY FEDAAC: 18F3AM ORDERING OFFICE: 787-767-3114		
C25-24	GASOHOL, REG UNL (GUR)	90,000	GL
	TANK WAGON (TW), INTO 2/5,000 GALLON TANK(S) ANTICIPATE 100% ON HIGHWAY USE		
C25-28	GASOLINE, REG UNL (MUR)	0	GL
	TANK WAGON (TW), INTO 2/5,000 GALLON TANK(S) ANTICIPATE 100% ON HIGHWAY USE NOTE: THIS IS AN ALTERNATE LINE ITEM FOR ITEM C25-24. AWARD WILL BE MADE AT THE OVERALL LEAST COST TO THE GOVERNMENT.		
	SAN JUAN PR, USPS, 00936-9721, VMG SAN JUAN MUNICIPALITY DELIVERY FEDAAC: 18F316 ORDERING OFFICE: 787-767-3114		
K25-24	GASOHOL, REG UNL (GUR)	165,000	GL
	TANK WAGON (TW), INTO 2/5,000 GALLON TANKS ANTICIPATE 100% ON HIGHWAY USE		
K25-28	GASOLINE, REG UNL (MUR)		
	TANK WAGON (TW), INTO 2/5,000 GALLON TANKS ANTICIPATE 100% ON HIGHWAY USE NOTE: THIS IS AN ALTERNATE LINE ITEM FOR ITEM K25-24. AWARD WIL BE MADE AT THE OVERALL LEAST COST TO THE GOVERNMENT		

C. The following Clause, specification applicable to Marine Gas Oil (Product Code 75), is hereby added to the Solicitation. The clause is included in full text, as follows:

**C16.23-2 COMMERCIAL MARINE GAS OIL MINIMUM SPECIFICATION REQUIREMENTS (DESC JAN 2001)**

Offered product shall conform to the following requirements that define a fuel suitable for Marine Gas Turbine engines.

<u>TEST</u>	<u>METHOD</u>	<u>REQUIREMENTS</u>
1. Cetane Number or Cetane Index	ASTM D 613  ASTM D 976	42 min  43 min

**NOTE:** The cetane index requirement shall apply to the base fuel without cetane improving additives, and the value shall be reported as the cetane index.

2. Appearance @ 21°C or ambient temp. (whichever higher) or Water & Sediment	Visual  ASTM D 2709	Clear & Bright  0.05 vol. % max.
3. Distillation, 90% point	ASTM D 86	357°C max.
4. Flash Point	ASTM D 93	60°C min

**NOTE:** The flash point value is absolute and no value less than 60°C is permissible.

5. Cloud Point	ASTM D 2500	-1.1°C (30°F) max.
----------------	-------------	--------------------

**NOTE:** Cloud Point results will be evaluated based upon bunkering location.

6. Viscosity @ 40°C	ASTM D 445	1.7 - 4.5 cSt
7. Color	ASTM D 1500	3 max.

**NOTE FOR DOMESTIC ITEMS:** This Color test requirement is deleted if red dye has been added in compliance with U.S. Environmental Protection Agency or Internal Revenue Service regulations; however, the resulting fuel/dye blend must have a red tint. It shall not be visually brown or darker in appearance.

**NOTE FOR OVERSEAS ITEMS:** Suppliers must submit information on the composition, color, and desired concentration of any dye to be used in order to obtain approval.

8. Density @ 15°C	ASTM D 1298	876 kg/m <sup>3</sup> max.
9. Carbon Residue on 10% bottoms	ASTM D 524 ASTM D 189	0.35 mass % max.
10. Ash	ASTM D 482	0.01 mass % max.
11. Sulfur	ASTM D 4294, ASTM D 1552, or ASTM D 2622	1.0 mass % max.

Clause C16.23-2 Continued

<u>TEST</u>	<u>METHOD</u>	<u>REQUIREMENTS</u>
12. Corrosion	ASTM D 130	3 max.
13. Distillate Fuel (fuel shall contain no residual)	None (DESC 52.246-9FAQ)	100%

D. All other Solicitation information is unchanged.