

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			<b>1. CONTRACT ID CODE</b> K	<b>PAGE</b> <b>1 OF 2</b>
<b>AMENDMENT/MODIFICATION NO.</b> 0002		<b>3. EFFECTIVE DATE</b> 21 December 2001	<b>4. REQUISITION/PURCHASE REQ. NO.</b> N/A	<b>5. PROJECT NO.</b> <i>(If applicable)</i>
<b>ISSUED BY</b> DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN ROAD, SUITE 4950 FT. BELVOIR, VA 22060-6222 FAX (703) 767-8757 BUYER/SYMBOL – B. JACKSON/DESC-EPP PHONE (703) 767-8534 P.P. 8.2		<b>CODE</b> SP0600	<b>7. ADMINISTERED BY</b> <i>(If other than Item 6)</i> <b>CODE</b>	
<b>NAME AND ADDRESS OF CONTRACTOR</b> <i>(NO., street, city, county, State, and ZIP Code)</i>			X	<b>9a. AMENDMENT OF SOLICITATION NO.</b> SP0600-01-R-0115
				<b>9b. DATED</b> <i>(SEE ITEM 11)</i> 26 September 2001
				<b>10a. MODIFICATION OF CONTRACT/ORDER NO.</b>
				<b>10b. DATED</b> <i>(SEE ITEM 13)</i>
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<p>X ] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  [ ] is extended, [ X ] is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR KNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>				
<b>12. ACCOUNTING AND APPROPRIATION DATA</b> <i>(If required)</i>				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. 12.05 CHANGES-FIXED PRICE (AUG 87)				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: FAR 43.01				
OTHER <i>(Specify type of modification and authority)</i>				
<b>3. IMPORTANT:</b> Contractor [ ] is not, [ ] is required to sign this document and return <u>1</u> copies to the issuing office.				
<b>4. DESCRIPTION OF AMENDMENT/MODIFICATION</b> <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i>				
Please see the following pages.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
<b>5A. NAME AND TITLE OF SIGNER</b> <i>(Type or print)</i>			<b>16A. NAME OF CONTRACTING OFFICER</b> BETTY A. HOAPILI	
<b>5B. NAME OF CONTRACTOR/OFFEROR</b> BY _____ <i>(Signature of person authorized to sign)</i>		<b>15C. DATE SIGNED</b>	<b>16B. UNITED STATES OF AMERICA</b> BY <i>Betty Hoapili</i> <i>(Signature of Contracting Officer)</i>	<b>16C. DATE SIGNED</b> 21 Dec 2001

The purpose of this amendment is to provide responses to questions proposed by prospective offerors concerning the solicitation and site visits.

Questions:

Q – What is the planned award date?

A – Dec 02.

Q – What percentage of contracts are actually being privatized?

A – To date, no ANG contracts have reached the award stage of the process.

Q – Are there emergency generators on the base?

A – Yes, they are auto-start and they are not included in the privatization contract.

Q – Do any of the transformers contain PCBs?

A – No, the last of the possible PCB-containing transformers were removed in 1993.

Q – Did the government hire a contractor to do the evaluation?

A – Contractors serve as advisors only, they are not voting members of the evaluation teams.

Q – Are the current capacities of the base utility systems sufficient to handle the current and forecasted loads?

A – Yes.

Q – Are there additional buildings planned?

A – Yes, some are under construction and some are planned. In each case, the utility systems are modified to handle the increased loads as required.

Q – Are the gas lines still steel or are they all plastic now?

A – Both steel and PVC lines exist on base.

Q – What happens if the base closes?

A – Paragraph 5.2 of the RFP covers this contingency.

Q – What is the 30,000-gallon propane tank for?

A – It provides backup fuel in the case of an emergency.

Q – Are the underground electrical lines in ductbanks?

A – Yes, all are in ductbanks and most are concrete encased.