

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE K	PAGE 1 OF 4
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE March 22, 2002	4. REQUISITION/PURCHASE REQ. NO. N/A		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN ROAD, SUITE 4950 FT. BELVOIR, VA 22060-6222 FAX (703) 767-8757 BUYER/SYMBOL – B. JACKSON/DESC-EPP PHONE (703) 767-8534 P.P. 8.2		7. ADMINISTERED BY <i>(If other than Item 6)</i> CODE		
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)		X	9a. AMENDMENT OF SOLICITATION NO. SP0600-01-R-0126	
			9b. DATED <i>(SEE ITEM 11)</i> 28 September 2001	
			10a. MODIFICATION OF CONTRACT/ORDER NO.	
			10b. DATED <i>(SEE ITEM 13)</i>	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<p>[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [X] is extended, [] is not extended to April 22, 2002 at 3:00 p.m. local time, Fort Belvoir, VA.</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>				
ACCOUNTING AND APPROPRIATION DATA <i>(If required)</i>				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. I2.05 CHANGES-FIXED PRICE (AUG 87)			
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)			
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: FAR 43.01			
	OTHER <i>(Specify type of modification and authority)</i>			
	E. IMPORTANT: Contractor [] is not, [] is required to sign this document and return _____ copies to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION <i>(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</i>				
* SEE ATTACHED.				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>		16A. NAME OF CONTRACTING OFFICER MICHAEL E. WHITE		
15B. NAME OF CONTRACTOR/OFFEROR BY _____ <i>(Signature of person authorized to sign)</i>	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY <u>Michael E. White</u> <i>(Signature of Contracting Officer)</i>	16C. DATE SIGNED 22 Mar 2002	

This amendment is issued to incorporate the following changes to Solicitation SP0600-01-R-0126:

- (1) **The due date for receipt of offers is hereby revised and extended to April 22, 2002, at 3:00 p.m. Eastern Standard Time.**
- (2) **Section J, Attachment J01, Fort Leonard Wood, MO Water Distribution System is hereby modified as follows:**
- (a) Section J01, Part J01.4.2, Required Secondary Meters - Table 6, New Secondary Meter, Water Distribution System - Fort Leonard Wood, page J01-6 have been modified as indicated below:

DELETE Table 6 in its entirety and **replace** with the following table:

Meter Location: Building Number	Description
Pence	Waynesville Schools
Pershing	Waynesville Schools
Pick	Waynesville Schools
Thayer	Waynesville Schools
Williams	Waynesville Schools
805	Davis Club
1382	MWR Car Wash 1
2030	Foster Lodge
2351	Boiler Plant and Laundry
4109	Pershing Club
7391	Audie Murphy Club

- (3) **Section J, Attachment J02, Fort Leonard Wood, MO Wastewater Collection System is hereby modified follows:**
- (a) Section J02, Part J02.2.2, Wastewater Collection System Non-Fixed Equipment and Specialized Tools Inventory Table 3, Specialized Equipment and Vehicles, Wastewater Collection System – Fort Leonard Wood, page J02-4.

DELETE the word, “None” from Table 3.

ADD the following entry:

Description	Quantity	Location	Maker
1995 Sludge Truck; Make/Model – 2204M Sludge; Serial No. – 2200765; 2,200-gallon capacity; semi-flotation tires; deflector sludge bar	1	Department of Public Works	N/A

(4) Responses to the questions proposed by prospective Offeror's:

1. **Q.:** What population growth is anticipated in the next five year and ten year periods? Is there a list of anticipated disconnections?
A.: Even though it is felt that the installation will grow gradually, there is no way to predict how much. There is a Master Planning Map in the technical library that shows new construction that the installation would like to do in the future. However, it depends on Congressional funding, which is uncertain. As far as disconnections, there is a small demolition program, but the buildings that are to be torn down are predicated on new buildings being built, which is uncertain as discussed above.
2. **Q.:** What were the original construct dollars expended in the 1980's for the WWTP improvements?
A.: The Wastewater Treatment Plant was constructed and turned over to the Army in 1980 with a cost of \$7,202,956.
3. **Q.:** What are the utility costs expended for operation of the lift stations, and WWTP including electric and propane? Will the military or will the new owner be responsible for these utility costs?
A.: The information is not available at this time.
4. **Q.:** We need copies of the Discharge Monitoring Reports on each of the WWTP's for the last 12 months as well as the State Discharge Permits.
A.: This information is available in the Technical Library.
5. **Q.:** Has there been any communication with Missouri DNR personnel regarding future discharge limitation restrictions regarding ammonia or chlorination. Is it anticipated that dechlorination will need to be added to the WWTP facility?
A.: It is the Installation's understanding that after 30 Dec 02, the permit will change allowing for a maximum of 14 mg/L of ammonia and 0.19 mg/L for chlorine. There is a project under design presently to use sulfur dioxide to dechlorinate. The plant is presently being monitored for ammonia by using existing plant treatment.
6. **Q.:** Are the laboratory cabinets and the analytical equipment a part of the property transfer?
A.: Yes, the list of specific equipment will be provided at a later time.
7. **Q.** Paragraph C.22 is conflicting. Please clarify.
A.: The transfer of the property is governed by the Easement or Bill of Sales and the sale/service is governed by the Federal Acquisition Regulation (FAR).
8. **Q.** Will the present liquid sludge application fields be included in the easement for WWTP usage?
A.: No.
9. **Q.:** Is the existing sewage collection system logged in a GIS format and will that information be provided in the transfer?
A.: Yes to both questions.

10. **Q.:** As per Addendum 0001, all the information is to be provided as one hardcopy in one three ring binder and two electronic copies of each file are to be placed on a CD. What directory names are requested for the two electronic file copies?
A.: Please label the CD's and use directory names, which identifies the contents incorporated.
- 11.:**Q.:** As per L.5, page 66, there is to be one original and three hard copies of the past performance information provided in four individual loose leaf binders. Please clarify if Addendum 0001 now supercedes L.5.
A.: Yes.
12. **Q.:** We request that a two week time extension be granted since the Technical Library was not made available till February 28, 2002. The present deadline allows less than 30 days to assimilate all the necessary technical information and to have the proposal mailed to Fort Belvoir by April 2, 2002.
A.: The solicitation is hereby extended to 22 Apr 02.
13. **Q.:** Are there any minimum Small Business Goals in the form of a percentage that we must meet under this potential contract?
A.: Yes, there are some small business percentages that are addressed in the Federal Acquisition Regulation (FAR). Please refer to FAR part 219.704 Subcontracting plan requirements.
14. **Q.:** What is the dollar value of the annual operations and maintenance contract with Rust Contractors. This contractor is presently operating and maintaining the wastewater plant and collection system.
A.: This information is not releasable.
15. **Q.** What volume of inflow and infiltration occurs at the three separate wastewater treatment facilities? Please provide all the smoke testing and/or televising records available on the sewer collection system.
A.: There are no smoke testing and/or televising records available. There has been no inflow/infiltration testing done recently. Almost all of the large sewer mains have been replaced within the last 10 years. Also, storm water is not connected to the sewer system.
16. **Q.** The RFP indicates that the minimum Federal Wage Rate for an operator is \$18.69 per hour plus fringe benefits. Should an entity other than the Federal government own, operate and maintain the wastewater collection and treatment system, are the federal wage rates still required to be paid?
A. The Department of Labor Wage Rates applicable to the Fort Leonard Wood area applies to any entity that enters into a Utility Privatization Contract with the Fort Leonard Wood Installation/Government.
17. **Q.:** Please provide a schematic of the wastewater treatment facilities identified by the respective NPDES permit Numbers of MO 0029769 and MO 0029777. Please provide a copy of these permits.
A. The requested prints and permits are available in the Technical Library.