

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE K		PAGE 1 OF 3
2. AMENDMENT/MODIFICATION NO. 0001		3. EFFECTIVE DATE 13 October 2004		4. REQUISITION/PURCHASE REQ. NO. SP0600-04-0560	
5. PROJECT NO. (If applicable)		6. ISSUED BY DEFENSE ENERGY SUPPORT CENTER 8725 JOHN J. KINGMAN ROAD, SUITE 3830 FT. BELVOIR, VA 22060-6222 BUYER/SYMBOL - M. NICHOLSON/DESC-EC PHONE (703) 767-9406		7. ADMINISTERED BY (If other than Item 6) CODE P.P. 8.2	
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)			9a. AMENDMENT OF SOLICITATION NO. SP0600-04-R-0109		
			9b. DATED (SEE ITEM 11) September 1, 2004		
			10a. MODIFICATION OF CONTRACT/ORDER NO.		
			10b. DATED (SEE ITEM 13)		
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. 12.05 CHANGES-FIXED PRICE (AUG 87)					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: FAR 43.01					
OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>    </u> copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
Please see the following pages.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME OF CONTRACTING OFFICER Kerri B. Chambers		
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY <i>Kerri B. Chambers</i> (Signature of Contracting Officer)		16C. DATE SIGNED <i>10/13/04</i>

1. This amendment is issued to incorporate the following changes to Solicitation SP0600-04-R-0109, Fort Huachuca Army Installation, Arizona.
2. All other terms and conditions remain the same.

**Section C.3.5 Energy/Water Commodity Supply, Page 15**

**DELETE** last sentence " The Contractor shall, however,...final discharge." Fort Huachuca must retain control of their wastewater throughout its life due to their water recharge and treated effluent programs, required by state environmental decisions.

**Section C.4.2 Use of Distribution Systems to Serve Areas Outside the Installation Service Area, Page 16**

**INSERT** after first sentence: "The Contractor may not use the utility infrastructure on the Installation to deliver wastewater or treated effluent to any area outside the service area."

**Section C.9.3 Construction and Restoration of Site, Page 21**

**ADD** to end of last sentence ", signage replacement and necessary repairs to all other property not owned by the Contractor."

**Section C.10 Environmental Compliance, Page 22**

**ADD** to end of sentence", and coordinate all construction and other applicable activities with Fort Huachuca's Environmental Division, Directorate of Installation Support."

**Section C.10.3 Environmental Impact Assessments, Page 23**

**ADD** to end of first sentence ", and the National Energy Policy Act (NEPA) in accordance with Fort Huachuca's Environmental Division, Directorate of Installation Support."

**Section L.2.1.6 Technical Library, Page 61**

In the first sentence, **DELETE** the word "priot" and replace with "prior".

**Section L.4.2 Subfactor 2: Operations and Maintenance/Quality Management Plan, Table L-1, Page 65**

**INSERT** under "Gas System" in place of "(Left Blank)" the word "Odorization."  
(continue to Page 66)

**CHANGE** under "Wastewater System": "Minimization of Inflow and Infiltration" to "Minimization of Inflow, Infiltration, and Exfiltration"

**INSERT** under all three systems after "Employee Certifications": "Force Protection"

**Section J02, Fort Huachuca Water Distribution System, J02.2 Water Distribution System Description, Page J02-2**

**ADD** new paragraph after second paragraph: "By the year 2011, Fort Huachuca's water usage must equal its aquifer recharge (provided by treated wastewater effluent and storm water). The goal for total annual pumping is 1,200 acre-feet or less per year by 2011. Details of this requirement can be found in the Technical Library in the Programmatic Biological Assessment and Opinion."

**Section J03, Fort Huachuca Wastewater System, J03.2.1.1 Description, Page J03-2**

**ADD** to end of first paragraph: "Recharge basin must be maintained to ensure percolation. Annual recharge volumes must be reported by the installation to the United States Fish and Wildlife Service as part of compliance with the Programmatic Biological Assessment and Opinion. The Contractor shall be required to comply with all current and future requirements of the Programmatic Biological Assessment and Opinion."