

Questions & Answers
SP0600-04-R-0097
Keesler Air Force Base, Mississippi

Question 1: Please confirm meaning of “SCLF” unit of measure for wire. This is assumed to mean “single conductor linear feet” or circuit feet, and would need to be multiplied by the number of wires in the circuit. Please confirm.

Response: Yes, multiply by number of conductors in the circuit.

Question 2: Please further describe “Disconnect Switch single pole”?

Response: We believe the inventory item referred to is residual military family housing electrical system components that should have been removed from the Table 1 inventory listing and is not included in the utility privatization RFP.

Question 3: Please further describe “Terminations, 25KV” ? Is this a cable “pothead” for terminating to air-break type padmount equipment and/or outdoor equipment?

Response: There are no 3-phase “pothead terminations on Keesler AFB. Terminations 25KV refer to either heat shrink or cold shrink high voltage terminations for connecting underground cable to “live front” or exposed high voltage bus switchgear or transformers.

Question 4: Please further describe “Elbow Connectors”? Are these 200-amp and 600-amp separable connectors, and their component parts, for transformer and equipment connections?

Response: The inventory line item is referring to the 200 Amp loadbreak or 600 Amp “dead break” elbow connectors for high voltage cable terminations in transformers, switching pedestals and switches.

***Note:** Government will modify Attachment J1 in the near future.